

Loss Prevention Certification Board



This is to certify

BALMORAL GROUP LIMITED

Balmoral Park, Loirston, Aberdeen AB12 3GY

is authorised to use the LPCB mark in association with the product listed in this certificate and appendix.

M100 Rectangular, Sectional, Hot Press Moulded GRP Panel Tank
(refer to attached appendix for details)

which have complied with the requirements of the following

LPS 1254: Issue 1 – Requirements for Suction Tanks
for Automatic Pumps

Certificate No. 445a


Issue No. 4

Date of Issue 29 March 2006

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Name: B.W. Lywood



LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 445a

BALMORAL GROUP LIMITED

Product Designation	Maximum capacity	LPCB Ref. No.
M100 rectangular, sectional, hot press moulded GRP panel tank. Maximum height 3m	192m ³	445a/01A
	192m ³	445a/01B
	192m ³	445a/01C
	192m ³	445a/01D

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Name: B.W. Lywood

Date of Issue 29 March 2006

Issue No. 4

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.